





TYBOX 33

www.deltadore.com



Important product information (24)

	2 x 1,5V LR03 - AAA Alkaline	230V~, 50 Hz +/- 10% 0,5 VA
Class		
	868 MHz (EN 300 220) 100 m	
	8 max.	
	/	2 A max., 230V~ (Type 1.C)
°C	-5°C / +40°C	
	80 x 103 x 25 mm	54 x 102 x 20 mm
IP	IP 30 - Vo	
CE	R&TTE 1999/5/CE	






MENU 2

2-01 Limitation consignes / Settings limitation / Limitación consignas / Limitação de recomendações / Limitazione valori di riferimento / Begrenzung der Sollwerte / Ograniczenie wartości zadane / Beperking ingestelde temperatuur / Omezení - pokyny / Anvisningsbegränsningar / Begrænsning indstillingsværdier / Begrensning i instruksene / Ohjeavojen rajoitus / 温度设定限制

2-02 Correction température mesurée / Measured temperature correction / Corrección temperatura medida / Correção da temperatura medida / Correzione temperatura misurata / Korrektur der gemessenen Temperatur / Korekta zmierzonych temperatury / Aanpassen gemeten temperatuur / Korekce měřené teploty / Uppmätt temperaturkorrigering / Korreksjon målt temperatur / Mitatun lämpötilan korjaus / 测量出的温度的校正



2-08 Base de temps de régulation / Regulation time base / Base de tiempos de regulación / Base de tempo de regulação / Base di tempo di regolazione / Zeitbasis für die Einstellung / Podstawa czasu regulacji / Basis voor instellingstijd / Báze doby regulace / Bas för inställningstid / Tidsbasis for regulering / Tidsenhet for regulering / Lämmönsäätelyn aikayksikkö / 调节时基


2-01	0	🔒	☀️ : 5°C < > 30°C
	1	🔒	❄️ : 5°C < > 15°C

2-08	15	Minutes
	30	Minutes
	45	Minutes
	60	Minutes

2-02 - 5°C < > +5°C



RESET



MODE

